

ROCKY MOUNT ENERGY RESOURCES
CREGF INTERCONNECTION INSTALLATION
METER BASE LABELING DIAGRAM
LESS THAN 10 KW CAPACITY

1. MINIMUM TEXT HEIGHT OF 3/8"
2. SIGNAGE SHALL BE MADE OF PLASTIC AND UTILIZE EMBOSSED LETTERING
3. SIGNAGE SHALL BE PERMANENTLY AFFIXED TO METER BASE COVER

